

"1+" or "3"

Notification No.: 1008

Test Report No.:

28210310 001

Order No.:

93356030

Page 1 / 2

Handwritten signature
B

Handwritten initials

Harmonised standard: EN 50575:2014 + A1:2016

Classification standard: EN 13501-6:2014

Throughout this report a comma is used as the decimal separator.

Abbreviations:
ok / P = passed
fail / F = failed
n.a. / N/A = not applicable
data / D = publication of data

This test report relates to the a_m_testItem. Without permission of the test center this test report is not permitted to be

www.tuv.hu

EN 60332-1-2

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

ZTT GYFJH-2F 7.0mm (ZTT 0959)

5 Procedure

Sample length (600 ± 25 mm).....	615		P
Approx. outer diameter (mm)	7.0		

6 Evaluation of test results

Not damaged area from lower edge of the top support (min. 50 mm).....	366		P
Damaged area from lower edge of the top support	498		P

No. of samples: 1

Ambient temperature: 26,5 °C

Date of test: 2017.03.07

Photo documentation**Before test****After test****Measurement list**

Device	Manufacturer	Type	Identification No.	Next calibration
Measuring tape	Stabila	BM 30W	503509	2019.09.21.
Stop-watch	Helvetia	S001	502911	2017.10.25.
Digital caliper	Mitutoyo	CD-15B	0556014003	2018.01.03

-END OF TEST REPORT-